

## **PROPANE STORAGE/INSTALLATION**

- Permit **\$50.00** obtained from the installer
- **Written notice** from Gas Co. (no gas service to street)
- **Plot plan** showing structural footprints and location of tanks
- Must comply with 527 CMR 1.00 Mass Amendments NFPA 1 2012 Ed and NFPA 58
- Inspection required after installation
- Plumbing inspector must also be notified (permit)
- Permit good for 3 yrs storage
- Re-New fee MGL Chap 148 Sections 10, 10A, and 37