

**TOWN OF ARLINGTON**  
**Purchasing Department**  
730 Massachusetts Avenue  
Arlington, MA 02476  
Telephone 781.316.3003

August 26, 2025

Invitation for Bids #25-52  
**Restoration of Iron Fencing – Mt Pleasant Cemetery**

**ADDENDUM NO. 1**

The attention of bidders submitting bids on the above-referenced project is called to the following Addendum to the Invitation for Bids. The items set forth herein, whether of omission, addition, substitution, or clarification, shall be included in and form a part of the proposal submitted and shall become part of the Contract.

**Questions from Bidders**

1. Can the work be done on site?

*Answer: No. The old paint may be lead-based and the work must be done off-site.*

All other terms and conditions of the Invitation for Bids remain unchanged.

**Bidders are advised to acknowledge this addendum on the bid form. Failure to acknowledge any or all addenda could result in rejection of the bid as non-responsive.**

James R. Feeney  
Town Manager